



## **Declaration of Conformity**

For the following equipmen	nt:		
Product Name: Switching I	Power Supply		
Model Designation: LRS-75-x (x=5,12,15,24,36,48)			
is herewith confirmed to c were applied :	comply with the requirements so	et out in the Council [	Directive, the following standards
RoHS Directive (2011	/65/EU)、(EU)2015/863		
Low Voltage Directive (	(2014/35/EU):		
EN61558-1:2005+A1:2009/EN61558-2-16:2009+A1 EN62368-1:2014+A11 EN60335-1:2012+A11/EN62233:2008		TUV certificate No: R50310933 TUV certificate No: R50426921 TUV certificate No: R50301056	
Electromagnetic Comp EMI (Electro-Magnetic In Conducted emission / Rad		/EU) :	Class B
Harmonic current	EN61000-3-2:2014		
Voltage flicker	EN61000-3-3:2013		
EMS (Electro-Magnetic S	Susceptibility)		
EN55024:2010+A1:2015 EN55014-2:2015 EN55035:2017 EN IEC61000-6-2:2019			
ESD air	EN61000-4-2:2009	Level 3	8KV
ESD contact	EN61000-4-2:2009	Level 2	4KV
RF field susceptibility	EN61000-4-3:2006+A1:2008-	+A2:2010 Level 3	10V/m
EFT bursts	EN61000-4-4:2012	Level 3	2KV/5KHz
Surge susceptibility	EN61000-4-5:2014+A1:2017	Level 4	2KV/Line-Line
Surge susceptibility	EN61000-4-5:2014+A1:2017	Level 4	4KV/Line-Earth
Conducted susceptibility	EN61000-4-6:2014	Level 3	10V
Magnetic field immunity	EN61000-4-8:2010	Level 4	30A/m
Voltage dip, interruption	EN61000-4-11:2004+A1:2017 >	95% dip 0.5 periods 30% dip	25 periods >95% interruptions 250 periods
enclosure. Since EMC perform EMC Directive on the complete The EMC tests mentioned abore For guidance on how to perform	nance will be affected by the comple e installation again. ove are performed using a well defir	te installation, the final equal ned metal plate to simulat to "EMI testing of compo	ts of an electronically shielded metal uipment manufacturers must re-qualify e said metal enclosure. nent power supplies".(as available on
This Declaration is effective fr	om serial number EB9xxxxxxx		
Person responsible for ma	rking this declaration:		
MEAN WELL Enterprises ( (Manufacturer Name) No.28, Wuquan 3rd Rd., W	Co., Ltd. Vugu Dist., New Taipei City 2489	91, Taiwan	
(Manufacturer Address)			
Johnny Huang/ Manager, Certification Center:  (Name / Position)  Alex Tsai/Director, Marketing Department:  (Signature)  (Signature)			
Taiwan	Nov 1st 2019		

(Date)

(Place)