



Declaration of Conformity

For the following equipment:

Product Name: Switching F	Power	Supplies
---------------------------	-------	----------

Model Designation: Rx-yz (x=S,D,ID,T,Q / y=125,150 / z=-3.3,-5,-12,-15,-24,-48,A,B,C,D, 1224, 1248, 2412,

2448, 4812, 4824); RID-125-1205; RID-125-2405; RS-150-7.5; RS-150-9; RS-150-19

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied:

RoHS Directive (2011/65/EU)

Low Voltage Directive (2014/35/EU):

EN60950-1:2006+A11+A1+A12 TUV certificate No : R50046942

Electromagnetic Compatibility Directive (2014/30/EU):

EN61000-4-5:2006

EN61000-4-5:2006

EMI (Electro-Magnetic Interference)

Conducted emission / Radiated emission

	EN55022:2010		Class B	
Harmonic current	EN61000-3-2:2006+A1:2009+A2:2009			
Voltage flicker	EN61000-3-3:2008			
EMS (Electro-Magnetic Susceptibility)				
EN55024:2010				
ESD air	EN61000-4-2:2009	Level 3	8KV	
ESD contact	EN61000-4-2:2009	Level 2	4KV	
RF field susceptibility	EN61000-4-3:2006+A1:2008+A2:2010	Level 3	10V/m	
EFT bursts	EN61000-4-4:2012	Level3	2KV/5KHz	

Conducted susceptibilityEN61000-4-6:2009Level 310VMagnetic field immunityEN61000-4-8:2010Level 430A/m

Voltage dip, interruption EN61000-4-11:2004 >95% dip 0.5 periods 30% dip 25 periods >95% interruptions 250 periods

Note

A component power supply with load will be installed into final equipment which consists of an electronically shielded metal enclosure. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again.

The EMC tests mentioned above are performed using a well defined metal plate to simulate said metal enclosure.

For guidance on how to perform these EMC tests, please refer to "EMI testing of component power supplies" (as available on http://www.meanwell.com)" and TDF (Technical Documentation File).

This Declaration is effective from serial number EB6xxxxxxx

Person responsible for marking this declaration:

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name)

Surge susceptibility

Surge susceptibility

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 248, Taiwan

(Manufacturer Address)

Johnny Huang/Manager, Certification Center: (Signature)

Ted Cheng/Director, Sales Dept.:

Level 3

Level 4

2KV/Line-Line

4KV/Line-Earth

(Name / Position)

Taiwan Apr. 20th, 2016 (Place) (Date)

(Signature)